SAFE DRINKING WATER & SANITARY CONDITIONS CERTIFICATE

No. 174 Dated: 08/5/26

It is certified that an inspection team headed by Dr Amarveer Singh from O/o Civil Surgeon Ferozepur , District Health officer Ferozepur inspected the Akal Academy Ratta Khera Village: Ratta Khera Tehsil: Zira, District: Ferozepur on 06/05/2026 and found that the Akal Academy Ratta Khera has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the State Govt.

The above is valid for a period of 1 Year from the date of Issuance.

Signature with Seal: .....

Name : Designated Officer O/o Civil Surgeon

Designation ..... Ferozepur .....

Name of the Office: .....

Principal
Akal Academy Ratta Khera
School Code : 21123
Affiliation No. : 1631133

MANAGER
AKAL ACADEMY
Ratta Khera Punjab Singh Wala
Ferozepur (Pb.)

DISTRICT WATER TESTING LABORATORY, FEROZPUR

Department of water supply and sanitation, zira gate, circular road, Ferozpur
dwtlfzr@gmail.com

TC-14027

TEST REPORT

Name & Address of Customer : **Principal Akal Academy ,VPO Rattakhera (Punjab Singh Wala) Tehsil & District-Ferozepur**		Customer Reference No.	**No : 66 Dated : 13/04/2026**
		Sample Submitted by	**Angrej Singh**
		Date of Sample Receipt	**23/04/2026**
		Analysis Starting Date	**23/04/2026**
		Analysis completion Date	**24/04/2026**
Discipline : **Chemical Testing**		Group: **Water**	
ULR No.:	**TC103752600000125F**	Sample Type :	**Water**
Test Report No.:	**DWTL/FZR/2627/00007**	Date of Issue :	**24/04/2026**
Registration no.:	**DWTL/FZR/REG2627/00037**	Condition of Sample :	**Sealed**
Collection Point:	**Private Submersible**	Quantity/Type of Bottle:	**1000 ml / Plastic Bottles**
Scheme/Source:	**Not Mentioned(Not Mentioned)**	Location/Depth :	**Akal Academy ,VPO Rattakhera (Punjab Singh Wala) Tehsil & District-Ferozepur / NA**
Village :	**Not Mentioned**	Habitation :	**Not Mentioned**
Block:	**Not Mentioned**	District :	**Ferozepur**
Latitude :	**Not Mentioned**	Longitude:	**Not Mentioned**

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	8.13@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	370	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	0.9	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	T. Alkalinity(CaCO3)	**244**	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	T. Hardness(CaCO3)	**220**	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	**80.1**	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	4.8	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	48	250	1000	mg/l.	IS 3025 (Part 32-2025) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't beused be as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, T=Total)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

Mrs. Manju
Quality Manager
Authorized Signatory
For,District Water Testing Laboratory
Ferozpur

End of the Test Report

Principal
Akal Academy,Ratta Khera
School Code : 21123
Affiliation No. : 1631133

MANAGER
AKAL ACADEMY
Ratta Khera Punjab Singh Wala
Ferozpur (Pb.)

DISTRICT WATER TESTING LABORATORY, FEROZPUR

Department of water supply and sanitation, zira gate, circular road, Ferozpur
dwtlfzr@gmail.com

To,

Principal
Akal Academy ,VPO Rattakhera (Punjab Singh Wala) Tehsil & District-Ferozepur

No.: DWTL/FZR/2627/00007 Dated : 24/04/2026

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. 66 Dated: 13/04/2026

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 23/04/2026. It is request to fill the attached feedback form and send it back to District Water Testing Laboratory, Ferozpur

D/A : Test Report

Authorized Signatory
For, District Water Testing Laboratory
Ferozpur

Principal
Akal Academy (Rattakhera)
School Code
Affiliation

MANAGER
AKAL ACADEMY
Rattakhera (Punjab Singh Wala)